

From: [Kristen Sargent](#)
To: [Cheryl Chrusz](#)
Cc: [Dawn Baker](#)
Subject: PB-07-23
Date: Monday, October 9, 2023 9:51:40 AM
Attachments: [image001.png](#)
[image002.png](#)

Chery,

The existing septic system serving the property must be properly abandoned at the time of demolition of the house. Our records do not indicate if the existing property is serviced by public water or a private well. This needs to be verified and if there is a private well, it must be abandoned by a NJ licensed well driller.

Regards,

Kristen Sargent, Sr. REHS

Montgomery Township Health Department
100 Community Drive
Skillman, NJ 08558
Phone (908)359-8211 ext 2250
ksargent@montgomerynj.gov

